


**CITY OF HALLANDALE BEACH, FLORIDA
MEMORANDUM**

DATE: July 13, 2009
TO: Christy Dominguez, Director of Planning and Zoning
FROM: Daniel Sullivan, Director, Department of Fire Rescue
SUBJECT: RENEWAL OF NIGHTCLUB LICENSES FOR FY 2009/2010

Fire staff conducted fire safety inspections of the Nightclubs referenced in your memo of June 26, 2009. The inspections revealed no significant threat to occupant safety and staff has no objections to their license renewals.

If you need further information please contact Inspector Lori Williams at extension 1478.

Prepared by:


Richard E. Stover, Division Chief, Fire Prevention and Public Education

CITY OF Hallandale Beach
Fire Prevention Bureau
121 South West 3 Street
Hallandale Beach, Florida 33009
PH. (954)457-1470 FAX (954)457-1472

Business Name: MANNY'S
Property Address: 23 NW 2 AVE
Location: Hallandale Beach, Fl 33009
Date: 840908
Inspection Type: 3/25/2009
Occ. License Inspection

Should this be Chapultepec Mexican Bar & Restaurant? SLC/CC

Fire Code Violations

Violation Number: 1
Violation Type: No fire code violations noted.
Violation Location: THROUGHOUT
Compliance Remedy: No compliance necessary.

Joseph Radler
Inspector

VIOLATIONS SHALL BE CORRECTED IMMEDIATELY

(2.)

City of Hallandale Beach
Fire Prevention Bureau
121 South West 3 Street
Hallandale Beach, Florida 33009
PH. (954)457-1470 FAX (954)457-1472

Business Name: Tatiana
Property Address: 1710 E Hallandale Beach Blvd
Hallandale Beach, FL 33009
Location: 838854
Date: 6/ 8/2009
Inspection Type: Annual

Fire Code Violations

Violation Number: 1
Violation Type: Other
Violation Location: MUST APPLY FOR PERMIT - CLOSET CLOSURE UNDER STAIRS
Compliance Remedy: .

Violation Number: 2
Violation Type: Hood system overdue for service.
Violation Location: DUE FOR SERVICE 6/2009 - APPLIANCES NOT PROTECTED
Compliance Remedy: System must be serviced and tagged on a six month basis.

Violation Number: 3
Violation Type: Stock too Close to Sprinkler Heads.
Violation Location: KITCHEN COOLER ALTERED - SPRINKLER HEAD TOO LOW
Compliance Remedy: Stock too Close to Sprinkler Heads.

Violation Number: 4
Violation Type: Fire alarm system needs service.
Violation Location: ALARM COMPANY MUST ELIMINATE BUZZING IN AUDIBLE UNITS
Compliance Remedy: Service fire alarm system immediately.

Violation Number: 5
Violation Type: Opening in walls/ceilings etc.
Violation Location: BEHIND STAGE - 2ND LEVEL - CLOSE CEILING/WALL OPENINGS
Compliance Remedy: Fix openings in walls/ceilings.

Lori Williams
Inspector

VIOLATIONS SHALL BE CORRECTED IMMEDIATELY

Business Name: Tatiana s
Property Address: 1710 E Hallandale Beach Blvd
Hallandale Beach, Fl 33009
Location: 838854
Date: 6/ 8/2009
Inspection Type: Annual

Fire Code Violations

Violation Number: 6
Violation Type: Special Hazards Category.
Violation Location: OUTDOOR SEATING AREA MUST HAVE FIRE SPRINKLER COVERAGE
Compliance Remedy: .

Violation Number: 7
Violation Type: Business is using extension cords/adaptors.
Violation Location: ORANGE EXTENSION CORD IN KITCHEN PREP-LOBBY
Compliance Remedy: Remove extension cords/adaptors, use proper electric.

Violation Number: 8
Violation Type: Fire extinguisher is missing.
Violation Location: BEHIND STAGE - 2ND LEVEL
Compliance Remedy: Install a 2A10BC fire extinguisher and mount on a wall.

Violation Number: 9
Violation Type: Fire sprinkler heads are painted.
Violation Location: COVERS MUST BE REPLACED - 2ND LEVEL BEHIND STAGE
Compliance Remedy: Replace all painted heads donot try to clean.

Lori Williams
Inspector

VIOLATIONS SHALL BE CORRECTED IMMEDIATELY

3.

**City of Hallandale Beach
Fire Prevention Bureau
121 South West 3 Street
Hallandale Beach, Florida 33009
PH. (954)457-1470 FAX (954)457-1472**

Business Name: FLANIGAN'S ENTPR INC #31

Property Address: 10 N FEDERAL HWY
Hallandale Beach, FL 33009

Location: 836786

Date: 9/24/2008

Inspection Type: Annual

Fire Code Violations

Violation Number: 1

Violation Type: Other.

Violation Location: RE AIM BROILER NOZZLES INTO BROILER. TO BE DONE BY PROFESSIONAL COMPANY

Compliance Remedy: .

Violation Number: 2

Violation Type: Business is using extension cords/adaptors.

Violation Location: BEHIND BROILERS

Compliance Remedy: Remove extension cords/adaptors, use proper electric.

**Charles Hackett
Inspector**

VIOLATIONS SHALL BE CORRECTED IMMEDIATELY

(4.)

CITY OF HALLANDALE BEACH
Fire Prevention Bureau
121 South West 3 Street
Hallandale Beach, Florida 33009
PH. (954)457-1470 FAX (954)457-1472

Business Name: GULFSTREAM RACE/TK GRANDSTAND
Property Address: 901 S FEDERAL HWY
Hallandale Beach, FL 33009
Location: 838802
Date: 6/18/2008
Inspection Type: Annual

Fire Code Violations

Violation Number: 1
Violation Type: Other
Violation Location: use loc #838803
Compliance Remedy: .

Brian Smith
Inspector

VIOLATIONS SHALL BE CORRECTED IMMEDIATELY

**City of Hallandale Beach
Fire Prevention Bureau
121 South West 3 Street
Hallandale Beach, Florida 33009
PH. (954)457-1470 FAX (954)457-1472**

Business Name: GULFSTREAM WRONG #USE 838802

Property Address: 901 S FEDERAL HWY
Hallandale Beach, Fl 33009

Location: 838803

Date: 6/30/2009

Inspection Type: Hazardous Material Permit

Fire Code Violations

Violation Number: 1

Violation Type: Business does not have a Haz. Mat permit.

Violation Location:

Compliance Remedy: Must apply for a Hazardous Material Permit.

**Jo Fearnley
Inspector**

VIOLATIONS SHALL BE CORRECTED IMMEDIATELY

City of Hallandale Beach
Fire Prevention Bureau
121 South West 3 Street
Hallandale Beach, Florida 33009
PH. (954)457-1470 FAX (954)457-1472

Business Name: GULFSTREAM WRONG #-USE 838802
Property Address: 901 S FEDERAL HWY
Hallandale Beach, FL 33009
Location: 838803
Date: 11/20/2008
Inspection Type: Annual

Fire Code Violations

Violation Number: 1
Violation Type: Special Hazards Category.
Violation Location: KITCHEN HOOD SYSTEMS DO NOT HAVE CORRECT COVERAGE - ALL
Compliance Remedy: .

Violation Number: 2
Violation Type: Special Hazards Category.
Violation Location: REPLACE ALL MISSING SPRINKLER ESCUTCHEON PLATES - THROUGHOUT
Compliance Remedy: .

Violation Number: 3
Violation Type: Special Hazards Category.
Violation Location: REPLACE ALL PAINTED SPRINKLER HEADS AND COVERS - THROUGHOUT
Compliance Remedy: .

Violation Number: 4
Violation Type: Improper lock on exit door.
Violation Location: 10 PALMS, SILKS & FINISH LINE CASINO - NO PANIC HARDWARE
Compliance Remedy: Must be changed to single cylinder thumb turn bolt.

Violation Number: 5
Violation Type: Ceiling tiles are missing in business.
Violation Location: REPLACE ALL MISSING CEILING TILE THROUGHOUT CLUBHOUSE
Compliance Remedy: Replace all missing ceiling tiles.

Lori Williams
Inspector

VIOLATIONS SHALL BE CORRECTED IMMEDIATELY

Business Name: GULFSTREAM WRONG #-USE 838802
Property Address: 901 S FEDERAL HWY
Hallandale Beach, Fl 33009
Location: 838803
Date: 11/20/2008
Inspection Type: Annual

Fire Code Violations

Violation Number: 6
Violation Type: Exitways are obstructed.
Violation Location: REMOVE ALL STORAGE FROM EXITWAYS/CORRIDORS/STAIRWELLS
Compliance Remedy: Must maintain 36 inch aisles to exits at all times.

Violation Number: 7
Violation Type: Electrical outlet cover plate missing.
Violation Location: CHECK ALL @ CEILING LEVELS AND BY MACHINERY
Compliance Remedy: Replace missing electrical cover plate.

Violation Number: 8
Violation Type: Extinguishers overdue for service.
Violation Location: BEHIND BAR @ CHRISTINE LEE'S, C408, B401
Compliance Remedy: Have extinguishers serviced immediately.

Violation Number: 9
Violation Type: Special Hazards Category.
Violation Location: FIRE RISER CAP MISSING @ TEAM EXIT TO STAIRWELL CM12
Compliance Remedy: .

Violation Number: 10
Violation Type: Special Hazards Category.
Violation Location: 10 PALMS HOOD, REMOVE FRYER WITH MELTED ELECTRIC CORD
Compliance Remedy: .

Violation Number: 11
Violation Type: Special Hazards Category.
Violation Location: REMOVE ALL GARBAGE CANS UNDER KITCHEN HOODS - MELTING
Compliance Remedy: .

Lori Williams
Inspector

VIOLATIONS SHALL BE CORRECTED IMMEDIATELY

Business Name: GULFSTREAM WRONG #-USE 838802
Property Address: 901 S FEDERAL HWY
Hallandale Beach, FI 33009
Location: 838803
Date: 11/20/2008
Inspection Type: Annual

Fire Code Violations

Violation Number: 12
Violation Type: Backflow preventor is overdue for certification.
Violation Location: ALL DORMS - ALL FIRE SERVICE BACKFLOWS
Compliance Remedy: Have backflow preventor tested and certified.

Violation Number: 13
Violation Type: Other.
Violation Location: SPRINKLER HEAD WRENCH MISSING @ DORM C
Compliance Remedy: .

Violation Number: 14
Violation Type: Special Hazards Category.
Violation Location: REPLACE ELECTRIC PANEL COVER IN MACHINERY ROOM - DORM A
Compliance Remedy: .

Violation Number: 15
Violation Type: Fire alarm system needs service.
Violation Location: BARNS - ALL FIRE ALARM TAGS EXPIRED OR NO DATE ON TAG
Compliance Remedy: Service fire alarm system immediately.

Violation Number: 16
Violation Type: Sprinkler system is missing the annual test.
Violation Location: BARNS - ALL RISER TAGS EXPIRED OR NO DATE
Compliance Remedy: Fire sprinkler system must be tested and certified annually.

Violation Number: 17
Violation Type: Business is using extension cords/adaptors.
Violation Location: OLD BARNS - REMOVE ALL EXTENSION CORDS
Compliance Remedy: Remove extension cords/adaptors, use proper electric.

Lori Williams
Inspector

VIOLATIONS SHALL BE CORRECTED IMMEDIATELY

Business Name: GULFSTREAM WRONG #-USE 838802
Property Address: 901 S FEDERAL HWY
Hallandale Beach, Fl 33009
Location: 838803
Date: 11/20/2008
Inspection Type: Annual

Fire Code Violations

Violation Number: 18
Violation Type: Special Hazards Category.
Violation Location: BARNS - CHECK ALL SPRINKLER HEADS/REPLACE BAGS
Compliance Remedy: .

Violation Number: 19
Violation Type: Business has improper electrical wiring.
Violation Location: MAINT BLDG - REAR SO. WALL - REMOVE YELLOW EXTENSION
Compliance Remedy: Install correct electrical wiring to meet NEC70.

Violation Number: 20
Violation Type: Extinguishers overdue for service.
Violation Location: CHECK BARNS 3, 5, 8, 12 AND 14
Compliance Remedy: Have extinguishers serviced immediately.

Violation Number: 21
Violation Type: Fire dept. connection is blocked or not visible.
Violation Location: BARN 18 - REMOVE DUMPSTER AND GATE CHAIN
Compliance Remedy: Make connection accessible to the fire dept.

Lori Williams
Inspector

VIOLATIONS SHALL BE CORRECTED IMMEDIATELY

**CITY OF Hallandale Beach
Fire Prevention Bureau
121 South West 3 Street
Hallandale Beach, Florida 33009
PH. (954)457-1470 FAX (954)457-1472**

Business Name: GULFSTREAM WRONG #-USE 838802

Property Address: 901 S FEDERAL HWY
Hallandale Beach, Fl 33009

Location: 838803

Date: 9/16/2008

Inspection Type: Other

Fire Code Violations

Violation Number: 1

Violation Type: Improper lock on exit door.

Violation Location: 10 PALMS/GROUND FLOOR CASINO AND SIMULCAST - NO PANIC HDWR

Compliance Remedy: Must be changed to single cylinder thumb turn bolt.

**Lori Williams
Inspector**

VIOLATIONS SHALL BE CORRECTED IMMEDIATELY

5.

**City of Hallandale Beach
Fire Prevention Bureau
121 South West 3 Street
Hallandale Beach, Florida 33009
PH. (954)457-1470 FAX (954)457-1472**

Business Name: HOLLYWOOD KENNEL CLUB

**Property Address: 831 N FEDERAL HWY
Hallandale Beach, Fl 33009**

Location: 836756

Date: 6/30/2009

Inspection Type: Hazardous Material Permit

Fire Code Violations

Violation Number: 1

Violation Type: Business does not have a Haz. Mat permit.

Violation Location:

Compliance Remedy: Must apply for a Hazardous Material Permit.

**Jo Fearnley
Inspector**

VIOLATIONS SHALL BE CORRECTED IMMEDIATELY

**CITY OF Hallandale Beach
Fire Prevention Bureau
121 South West 3 Street
Hallandale Beach, Florida 33009
TEL (954)457-1470 FAX (954)457-1472**

Business Name: HOLLYWOOD KENNEL CLUB
Property Address: 831 N FEDERAL HWY
Hallandale Beach, Fl 33009
Location: 836756
Date: 7/18/2008
Inspection Type: Annual

Fire Code Violations

Violation Number: 1
Violation Type: No fire code violations noted.
Violation Location: PROPERTY UPGRADING UNDER PERMIT - ONGOING INSPECTIONS
Compliance Remedy: No compliance necessary.

**Lori Williams
Inspector**

VIOLATIONS SHALL BE CORRECTED IMMEDIATELY

(6.)

**CITY OF Hallandale Beach
Fire Prevention Bureau
121 South West 3 Street
Hallandale Beach, Florida 33009
PH. (954)457-1470 FAX (954)457-1472**

Business Name: OCEANS 11/DBA Marjorie Gallage
Property Address: 800 N FEDERAL HWY
Hallandale Beach, FL 33009
Location: 188160
Date: 7/ 3/2008
Inspection Type: Annual

Fire Code Violations

Violation Number: 1
Violation Type: No fire code violations noted.
Violation Location: THROUGHOUT
Compliance Remedy: No compliance necessary.

Charles Hackett
Inspector

VIOLATIONS SHALL BE CORRECTED IMMEDIATELY

City of Hallandale Beach
Fire Prevention Bureau
121 South West 3 Street
Hallandale Beach, Florida 33009
PH. (954)457-1477 FAX

Business Name: A-1 Florist & Exquisite Events
Property Address: 103 ne 3 st
Hallandale Beach, Fl 33009
Location: 842,240
Date: 7/29/2009
Inspection Type: 1st Reinspection

Fire Code Violations

Violation Number: 1
Violation Type: Previous Violations are Corrected.
Violation Location: Throughout bussiness
Compliance Remedy: Previous Violations are Corrected.

Miguel Aleman
Inspector

VIOLATIONS SHALL BE CORRECTED IMMEDIATELY
